

# *Certificate of Performance*

*On this date the cleanroom facilities of*

## ***Brentwood Industries CEMA Cleanroom***

*Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during an "operational" state.*

*Work Cell A - ISO Class 6 at 0.5  $\mu$ m*

*Work Cell B and Raw Material Room - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu$ m*

*Gowning Room - ISO Class 7 at 0.5 & 1.0  $\mu$ m*

*Work Cell D and Quality Inspection - ISO Class 7 at 1.0 & 5.0  $\mu$ m*

*Work Cell C - ISO Class 7 at 5.0  $\mu$ m*

*NEBB Certified Firm: Air Filtration Management, Inc.*

*Phone: (610) 867-3869*

*[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)*

*NEBB Certification Number: 104*

*NEBB CPT Professional: William M. Bock*

*Signature: William M. Bock*

*Test Date: April 2017 Retest Date: April 2018*

**National Environmental Balancing Bureau**

