

May 1, 2020

Brentwood Industries, Inc.  
621 Brentwood Drive  
Reading, PA 19611

Attn: Mr. Cristian Avalos  
Department Manager

RE: CEMA CLEANROOM  
PERFORMANCE EVALUATION TESTING AND CERTIFICATION SERVICE  
AFM PROJECT #2020139; SUBMITTAL #01

Dear Mr. Avalos:


We are pleased to submit to you our preliminary project report highlighting the test results from the Independent, NEBB Certified Performance Evaluation Testing and Certification Service performed in the CEMA Cleanroom at the Brentwood Industries facility located in Reading, Pennsylvania. Testing was performed in accordance with NEBB Procedural Standards, International Standard 14644-1:2015 and IEST-RP-CC006.3.

Airborne particle counts were sampled and recorded on test matrices to meet the requirements of International Standard ISO 14644-1:2015. All areas were found to either meet or exceed their respective design cleanliness classifications of ISO Class 8. Reference the following chart for the certified cleanliness classes achieved within each area during respective occupancy state.

Area	“Operational” Occupancy State	“At-Rest” Occupancy State
Gowning Room	ISO Class 7 @ 0.5 & 1.0 µm	ISO Class 6 @ 0.5 µm
Raw Material Room	ISO Class 7 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell A	ISO Class 6 @ 0.3, 0.5 & 1.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell B	ISO Class 7 @ 0.5, 1.0 & 5.0 µm	ISO Class 5 @ 0.3 µm
Work Cell C	ISO Class 6 @ 0.5 & 1.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell D	ISO Class 6 @ 0.3, 0.5 & 1.0 µm	ISO Class 5 @ 0.3 µm
Quality Inspection	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm

We trust you have found this preliminary report satisfactory as we have appreciated this opportunity to be of continued service to Brentwood Industries. Please do not hesitate to contact us should you have any questions prior to the issuance of the final report.

Sincerely,  
Air Filtration Management, Inc.



Ryan M. Kelly  
Project Manager/ NEBB CPT Technician

Air Filtration Management, Inc.



Michael J. Kelly  
NEBB CPT Professional