

Certificate of Performance

On this date the cleanroom facilities of
Brentwood Industries, Inc.
CEMA Cleanroom

Have been tested in accordance with NEBB Procedural Standards for
Certified Testing of Cleanrooms to meet the following air cleanliness classification
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.

Room Name	“Operational” Occupancy State	“At-Rest” Occupancy State
Gowning Room	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm
Raw Material Room	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell A	ISO Class 7 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm
Work Cell B	ISO Class 7 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm
Work Cell C	ISO Class 7 @ 0.5 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell D	ISO Class 7 @ 0.5 & 1.0 µm	ISO Class 6 @ 0.3 & 0.5 µm
Quality Inspection & Analysis Area	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm


NEBB Certified Firm: **Air Filtration Management, Inc.**

Phone: (610) 867-3869

www.airfiltrationmgmt.com

NEBB Certification Number: 104

NEBB CPT Professional: **Michael J. Kelly**

Signature: 

Test Date: **April 2021** Retest Date: **April 2022**

National Environmental Balancing Bureau

