

# Certificate of Performance

On this date the cleanroom facilities of

## **Brentwood Industries, Inc.** **CEMA Cleanroom**

*Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

Room Name	"Operational" Occupancy State	"At-Rest" Occupancy State
Gowning Room	ISO Class 6 @ 0.3 & 5.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Raw Material Room	ISO Class 7 @ 5.0 µm	ISO Class 7 @ 1.0 µm
Work Cell A	ISO Class 6 @ 0.5 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell B	ISO Class 6 @ 0.5 µm	ISO Class 6 @ 0.5 & 1.0 µm
Work Cell C	ISO Class 7 @ 5.0 µm	ISO Class 6 @ 0.3, 0.5 & 1.0 µm
Work Cell D	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 6 @ 0.3 & 0.5 µm
Quality Inspection & Analysis Area	ISO Class 8 @ 0.5, 1.0 & 5.0 µm	ISO Class 7 @ 1.0 & 5.0 µm

NEBB Certified Firm: **Air Filtration Management, Inc.**

Phone: (610) 867-3869

[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)

NEBB Certification Number: 104

NEBB CPT Professional: **Michael J. Kelly**

Signature: 

Test Date: **May 2022** Retest Date: **May 2023**

**National Environmental Balancing  
Bureau**

