

Certificate of Performance

On this date the cleanroom facilities of
Brentwood Industries, Inc.
CEMA Cleanroom

*Have been tested in accordance with NEBB Procedural Standards for
Certified Testing of Cleanrooms to meet the following air cleanliness classification
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

| Room Name | "Operational" Occupancy State | "At-Rest" Occupancy State |
|------------------------------------|-------------------------------|---------------------------------|
| Gowning Room | ISO Class 6 @ 0.3 & 0.5 µm | ISO Class 5 @ 0.3 & 0.5 µm |
| Raw Material Room | ISO Class 6 @ 0.3 & 0.5 µm | ISO Class 5 @ 0.3 µm |
| Work Cell A | ISO Class 6 @ 0.3 & 0.5 µm | ISO Class 5 @ 0.3 & 0.5 µm |
| Work Cell B | ISO Class 6 @ 0.3 & 0.5 µm | ISO Class 6 @ 0.3, 0.5 & 1.0 µm |
| Work Cell C | ISO Class 7 @ 0.5 & 1.0 µm | ISO Class 6 @ 0.3, 0.5 & 1.0 µm |
| Work Cell D | ISO Class 6 @ 0.3 µm | ISO Class 6 @ 0.3 & 0.5 µm |
| Quality Inspection & Analysis Area | ISO Class 6 @ 0.3 & 0.5 µm | ISO Class 6 @ 0.3, 0.5 & 1.0 µm |

NEBB Certified Firm: Air Filtration Management

Phone: (610) 867-3869

www.airfiltrationmgmt.com

NEBB Certification Number: 3898

NEBB CPT Professional: Michael J. Kelly

Signature: 

Test Date: April 2025 Retest Date: April 2026

National Environmental Balancing Bureau

